

# 大涌镇污水处理厂每月运行情况记录表

企业单位名称(盖章): 大涌镇污水处理有限公司

填报日期: 2021年1月

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率 80%) (千 克)	回用水量 (万吨)	用电量 (千瓦 时)	备注
		进水	出水	进水	出水				
1	1.38	93.0	12.0	22.80	0.84	7.97			
2	1.38	261.0	8.0	25.20	2.23	7.48			
3	1.20	119.0	7.0	23.50	3.44	7.62			
4	1.44	151.0	8.5	9.80	0.48	7.83			
5	1.18	175.0	6.5	20.40	0.30	7.78			
6	1.15	186.0	10.0	22.60	1.80	9.03			
7	1.16	222.0	7.0	25.30	0.46	7.51			
8	1.07	220.0	12.0	25.50	0.55	17.52			
9	1.34	148.0	10.5	20.60	1.35	12.12			
10	0.82	216.0	12.0	23.80	1.84	10.08			
11	0.89	138.0	9.0	26.10	1.41	16.26			
12	1.07	197.0	17.0	27.20	2.76	15.11			
13	0.48	136.0	0.0	25.80	0.89	16.22			
14	0.13	104.0	13.0	21.50	0.37	7.19			
15	0.31	156.0	8.5	24.90	3.28	7.82			
16	0.30	65.0	6.0	18.20	0.55	7.98			
17	0.44	117.0	9.0	25.00	1.06	8.51			
18	0.35	108.0	7.5	22.70	1.97	8.44			
19	0.37	98.0	13.0	23.60	0.20	8.06			
20	0.35	132.0	8.5	22.00	1.55	8.58			
21	1.08	215.0	9.5	20.20	0.23	7.91			
22	1.23	118.0	19.0	5.58	0.64	7.66			
23	1.05	94.0	20.0	8.92	0.97	8.04			
24	1.39	83.0	20.0	9.75	1.08	8.03			
25	1.30	127.0	21.0	13.80	1.07	7.76			
26	1.22	156.0	15.5	8.58	1.20	6.58			
27	1.03	105.0	21.0	10.20	2.19	7.23			
28	0.89	136.0	18.0	12.40	0.83	7.42			
29	0.60	109.0	18.5	11.00	2.09	7.12			
30	0.74	90.0	11.5	13.70	1.33	7.45			
31	0.80	65.0	14.0	16.90	0.70				
合计 (或加 权平 均)	28.15	140.00	12.03	18.95	1.28	274.31			

113010

COD、氨  
氮进水、  
出水浓度  
为企业自  
测数据。

# 大涌镇污水处理厂每月运行情况记录表

企业单位名称(盖章): 大涌镇污水处理有限公司

填报日期: 2021年2月

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率 80%) (千 克)	回用水量 (万吨)	用电量 (千瓦 时)	备注
		进水	出水	进水	出水				
1	0.52	233.0	14.0	20.30	0.958	16.40			
2	0.61	115.0	3.5	16.30	1.020	8.60			
3	0.53	312.0	10.0	14.20	0.055	7.50			
4	0.52	184.0	7.0	14.30	0.140	8.57			
5	0.44	82.0	9.0	22.80	0.077	6.89			
6	0.27	130.0	12.0	14.10	2.810				
7	0.32	99.0	13.0	18.60	3.310	7.02			
8	0.28	86.0	15.0	15.80	0.996	8.73			
9	0.32	58.0	9.0	24.20	2.050	7.19			
10	0.49	63.0	17.0	15.80	0.452	8.18			
11	0.33	126.0	18.0	13.40	1.560				
12	0.69	74.0	14.5	13.40	0.838				
13	0.78	59.0	10.5	15.28	2.450	8.28			
14	1.03	66.0	8.0	15.85	1.490	7.95			
15	0.77	60.0	5.0	16.70	2.660				
16	0.57	55.0	17.5	17.40	3.660	6.87			
17	0.83	51.0	11.0	14.20	1.410				
18	0.84	76.0	8.5	18.30	0.202	7.44			
19	0.79	71.0	10.0	16.90	0.670	7.94			
20	0.85	128.0	11.0	18.90	0.168	9.06			
21	0.95	44.0	16.0	22.00	0.264				
22	0.92	52.0	15.0	25.20	1.840	8.41			
23	0.91	65.0	3.0	25.70	2.820	7.87			
24	0.92	98.0	10.0	25.80	0.748	8.23			
25	1.10	114.0	16.0	15.90	0.102	7.88			
26	1.14	178.0	20.0	11.80	0.176	8.33			
27	0.91	91.0	14.5	12.40	0.248	8.09			
28	1.02	117.0	14.0	18.70	0.236				
合计 (或加 权平 均)	19.67	103.11	11.86	17.65	1.19	175.43			

85725

COD、氨氮进水、出水浓度为企业自测数据。

# 大涌镇污水处理厂每月运行情况记录表

企业单位名称(盖章): 大涌镇污水处理有限公司

填报日期: 2021年3月

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率 80%) (千 克)	回用水量 (万吨)	用电量 (千瓦 时)	备注
		进水	出水	进水	出水				
1	1.33	95	17.5	15.00	0.24	15.91			COD、氨 氮进水 、出水 浓度为 企业自 测数据 。
2	1.29	72	19.0	12.30	0.59	9.00			
3	1.12	157	21.5	10.60	1.01	7.93			
4	1.24	149	14.0	17.80	1.03	7.95			
5	0.71	151	24.5	16.10	2.77	7.66			
6	0.42	185	18.5	21.90	1.68	8.05			
7	0.32	150	12.0	23.80	1.10	6.17			
8	0.69	112	18.0	15.80	0.34	8.21			
9	1.22	125	28.0	19.00	0.25	7.06			
10	1.22	149	20.0	14.80	0.47	9.46			
11	1.11	130	28.0	13.60	1.00	8.37			
12	0.76	211	16.0	19.40	3.14	8.47			
13	1.19	155	23.0	22.60	1.03				
14	1.26	149	24.5	12.40	0.38	8.12			
15	1.16	137	22.0	15.20	0.39	7.66			
16	1.24	134	20.5	14.50	0.44	7.75		114750	
17	0.77	243	21.0	17.80	3.45	8.09			
18	0.52	225	11.0	25.60	1.56	8.52			
19	0.51	207	13.0	29.40	0.26	7.90			
20	0.70	176	15.5	37.90	0.28	7.73			
21	0.72	122	25.5	39.20	0.19				
22	0.56	218	14.0	42.60	0.20	8.72			
23	0.60	170	6.0	40.30	0.42	8.50			
24	0.60	125	11.0	41.60	0.16	8.08			
25	0.57	170	1.0	32.60	0.35	8.37			
26	0.58	97	11.0	36.00	0.25	8.51			
27	0.58	135	12.0	41.10	0.24				
28	0.34	164	13.0	43.10	0.78				
29	0.37	157	11.0	34.00	0.24	6.86			
30	0.13	129	8.0	38.90	0.40	7.94			
31	0.15	136	8.0	35.30	0.13				
合计 (或加 权平 均)	23.99	153	16.4	25.81	0.80	216.99			

# 大涌镇污水处理厂每月运行情况记录表

企业单位名称(盖章): 大涌镇污水处理有限公司

填报日期: 2021年4月

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率 80%) (千 克)	回用水量 (万吨)	用电量 (千瓦 时)	备注
		进水	出水	进水	出水				
1	0.28	235	7.5	45.45	0.16	4.00			
2	0.80	148	7.5	47.85	0.21	3.19			
3	0.96	126	7.5	17.58	0.31	4.00			
4	1.40	139	7.5	7.15	0.22				
5	1.47	149	34.0	5.60	0.50	4.14			
6	1.60	150	25.0	8.90	0.98	4.00			
7	1.42	94	22.0	6.05	0.24	3.54			
8	1.31	205	7.5	7.12	0.74	4.00			
9	0.73	102	19.0	12.42	0.78	4.52			
10	1.15	190	7.5	7.18	0.25				
11	1.17	209	7.5	4.52	0.24	8.27			
12	1.31	181	24.0	6.10	0.29	7.97			
13	1.32	140	22.0	5.10	0.39	14.21			
14	1.39	149	7.5	5.20	0.28	5.62			
15	0.92	167	23.0	11.25	1.96	5.00			
16	0.64	245	25.5	10.15	3.27	4.09		125595	
17	0.48	145	7.5	22.48	0.84	7.25			
18	0.48	179	7.5	15.92	1.99				
19	0.99	157	15.5	16.60	0.31	7.88			
20	0.79	433	16.0	11.58	0.16	7.36			
21	0.74	125	7.5	23.58	0.20	7.32			
22	1.12	178	24.0	19.62	0.31	7.81			
23	1.47	136	27.0	7.12	0.45	6.98			
24	1.32	183	7.5	7.60	0.87				
25	1.23	138	15.0	11.32	1.94	7.65			
26	1.58	149	25.0	9.85	2.32	15.06			
27	1.76	160	12.0	8.28	0.44				
28	1.84	171	22.0	6.35	2.24	7.41			
29	1.90	484	11.0	3.70	0.49	12.28			
30	1.73	151	15.0	8.82	0.55				
合计 (或加 权平 均)	35.29	181	15.6	12.68	0.80	163.55			COD、氨 氮进水、 出水浓度 为企业自 测数据。

# 大涌镇污水处理厂每月运行情况记录表

企业单位名称(盖章): 大涌镇污水处理有限公司

填报日期: 2021年5月

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率 80%) (千 克)	回用水量 (万吨)	用电量 (千瓦 时)	备注
		进水	出水	进水	出水				
1	1.73	172	15.0	10.20	1.38				
2	0.74	111	7.5	19.45	0.95	8.09			
3	0.61	112	7.5	19.85	1.89				
4	1.32	148	17.0	11.18	0.23	7.23			
5	0.88	166	7.5	19.68	1.17	6.15			
6	1.25	178	7.5	8.08	0.26	6.98			
7	1.16	132	7.5	9.72	0.26	14.36			
8	1.60	173	7.5	17.08	0.26	7.52			
9	1.59	152	7.5	8.28	0.45	6.39			
10	1.57	181	7.5	17.18	0.41	8.08			
11	1.41	130	7.5	12.10	0.41	6.75			
12	1.55	122	18.0	17.05	1.06	7.52			
13	1.55	138	16.0	14.20	0.77	7.08			
14	1.45	366	15.0	13.38	1.72	7.75			
15	1.51	149	15.0	12.60	1.43				
16	1.71	112	18.0	11.22	1.56	7.01		155160	COD、氨 氮进水、 出水浓度 为企业自 测数据。
17	1.51	89	18.0	11.12	1.56	5.60			
18	1.59	121	23.0	8.02	2.40	5.76			
19	1.57	110	10.0	11.32	2.21	4.00			
20	1.57	138	18.0	13.85	2.57	3.46			
21	1.18	105	10.0	13.72	2.87	4.00			
22	1.36	139	7.5	7.95	0.34	3.67			
23	1.61	301	20.0	18.22	1.83				
24	1.47	138	7.5	12.50	1.22	5.00			
25	1.01	154	16.0	28.42	2.78	4.43			
26	1.18	425	7.5	23.32	0.44	2.00			
27	0.89	111	7.5	18.50	3.13	2.00			
28	1.02	104	15.0	24.75	0.37	3.38			
29	1.49	120	7.5	7.15	1.05				
30	1.80	108	7.5	10.05	0.65				
31	1.52	107	7.5	12.40	1.83				
合计 (或加 权平 均)	42.42	155	11.7	14.28	1.27	144.21			

# 大涌镇污水处理厂每月运行情况记录表

企业名称名称(盖章): 大涌镇污水处理有限公司

填报日期:

2021年6月

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率 80%) (千 克)	回用水量 (万吨)	用电量 (千瓦 时)	备注
		进水	出水	进水	出水				
1	1.11	128	16.0	16.38	0.94	6.52			
2	1.59	85	7.5	17.40	3.15				
3	1.04	63	18.0	13.00	0.15				
4	1.48	160	16.0	14.97	0.39				
5	1.28	99	7.5	11.38	0.22				
6	1.62	68	7.5	12.18	1.18				
7	1.34	123	7.5	13.80	1.44	6.91			
8	1.23	147	16.0	13.35	0.31				
9	1.74	83	17.0	13.82	0.82	7.05			
10	1.46	92	17.0	16.60	0.99	8.53			
11	1.13	83	19.0	20.22	0.13	7.86			
12	1.72	106	7.5	14.28	0.29				
13	1.95	103	20.0	13.92	0.40				
14	2.05	66	7.5	8.20	0.16				
15	1.75	60	7.5	9.15	0.32	6.69			
16	1.92	70	18.0	12.08	0.36	6.88			
17	1.70	332	7.5	14.82	0.40				
18	1.29	111	16.0	14.90	0.52	7.25			
19	0.83	140	7.5	18.45	0.07				
20	1.18	87	7.5	25.54	0.12				
21	1.47	129	7.5	23.87	0.23				
22	1.54	114	7.5	27.04	0.09				
23	1.60	103	7.5	14.80	0.11	7.64			
24	1.75	96	7.5	8.77	0.09	7.52			
25	1.33	125	7.5	14.42	0.12	6.77			
26	1.01	121	7.5	23.51	0.19				
27	1.26	104	7.5	23.10	0.08				
28	0.91	116	7.5	22.50	0.08	7.48			
29	1.05	136	7.5	23.99	0.24				
30	0.81	105	7.5	26.49	0.08	7.73			
31									
合计 (或加 权平 均)	42.17	112	10.8	16.76	0.46	94.83			

150300

COD、氨氮进水、出水浓度为企业自测数据。

# 大涌镇污水处理厂每月运行情况记录表

企业单位名称(盖章): 大涌镇污水处理有限公司						填报日期:	2021年7月		
日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率 80%) (千 克)	回用水量 (万吨)	用电量 (千瓦 时)	备注
		进水	出水	进水	出水				
1	1.13	108	7.5	26.64	0.07	8.39			
2	1.54	95	7.5	25.78	0.06				
3	1.62	95	16.0	17.93	0.10				
4	0.83	113	24.0	23.26	0.08	6.48			
5	0.58	112	28.0	23.98	0.09				
6	0.61	91	19.0	26.44	0.07				
7	0.85	83	7.5	25.34	0.07				
8	1.49	88	7.5	26.64	0.08				
9	1.32	105	16.0	22.99	0.08				
10	1.25	124	22.0	30.79	0.08				
11	1.28	148	7.5	32.72	0.17				
12	0.98	168	15.0	35.58	0.08				
13	0.98	135	7.5	29.08	0.08	8.19			
14	1.15	156	7.5	33.56	0.10				
15	0.81	186	15.0	28.20	0.04	7.20			
16	0.63	125	7.5	21.65	1.24	8.49		129570	COD、氨氮进水、出水浓度为企业自测数据。
17	0.51	261	7.5	27.44	4.38	4.97			
18	0.27	78	23.0	18.61	0.19				
19	0.17	132	17.0	13.38	0.13				
20	1.16	134	15.0	20.50	0.06				
21	1.42	272	7.5	5.85	0.06				
22	1.47	69	18.0	8.26	0.09				
23	1.07	61	7.5	13.45	0.10	6.58			
24	1.10	76	7.5	19.33	0.12	7.02			
25	1.23	106	16.0	20.80	0.15				
26	1.24	93	7.5	23.46	0.16	7.74			
27	0.92	128	7.5	24.42	0.07	6.23			
28	1.03	109	7.5	24.50	0.08				
29	1.05	104	16.0	21.42	0.48	7.50			
30	1.03	133	7.5	29.28	0.66				
31	1.39	199	7.5	27.28	1.44	7.50			
合计 (或加权平均)	32.15	125	12.5	23.50	0.34	86.29			

# 大涌镇污水处理厂每月运行情况记录表

企业单位名称(盖章): 大涌镇污水处理有限公司						填报日期:	2021年 8月		
日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率 80%) (千 克)	回用水量 (万吨)	用电量 (千瓦 时)	备注
		进水	出水	进水	出水				
1	1.25	143	16.0	24.32	0.54				
2	0.93	191	15.0	17.99	0.13	5.98			
3	1.34	103	7.5	18.54	0.51	6.39			
4	1.42	114	7.5	15.51	0.07	8.32			
5	1.57	170	16.0	14.85	0.09	6.66			
6	1.36	116	7.5	15.85	0.08				
7	0.99	195	7.5	24.64	0.07				
8	0.97	160	7.5	16.24	0.17	7.05			
9	0.98	117	7.5	18.44	0.07				
10	2.23	81	15.0	12.23	0.13	7.65			
11	2.14	63	7.5	9.84	0.08				
12	1.27	96	19.0	14.18	0.24	8.93			
13	1.30	107	7.5	20.55	0.10				
14	1.95	173	7.5	21.58	0.08				
15	0.81	88	17.0	17.66	0.07				
16	0.82	145	7.5	23.97	0.23	7.20		138240	COD、氨 氮进水、 出水浓度 为企业自 测数据。
17	1.08	135	7.5	24.64	0.10				
18	0.58	93	7.5	17.96	1.47	7.36			
19	0.65	107	7.5	21.31	2.47				
20	1.15	108	7.5	22.57	2.39				
21	1.35	153	17.0	29.69	2.81	7.93			
22	1.24	147	7.5	29.72	0.78				
23	0.84	156	7.5	30.34	0.16				
24	0.60	156	15.0	28.69	0.50	8.28			
25	1.05	136	7.5	25.93	0.16				
26	0.93	115	18.0	20.55	0.15	7.57			
27	1.67	107	7.5	17.19	0.15				
28	1.69	219	7.5	18.29	0.21				
29	1.46	142	7.5	13.88	0.10	7.45			
30	2.08	162	20.0	24.00	0.11				
31	1.92	316	7.5	13.22	0.19	7.61			
合计 (或加 权平 均)	39.61	139	10.5	20.14	0.46	104.38	0.00		



# 大涌镇污水处理厂每月运行情况记录表

企业单位名称(盖章): 大涌镇污水处理有限公司 填报日期: 2021年9月

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率 80%) (千 克)	回用水量 (万吨)	用电量 (千瓦 时)	备注
		进水	出水	进水	出水				
1	2.27	225	7.5	17.13	0.21				
2	2.03	226	7.5	24.57	0.06	7.44			
3	2.02	415	7.5	17.13	0.09	6.25			
4	2.00	374	7.5	20.87	0.67				
5	1.85	594	7.5	25.87	0.10				
6	2.41	261	7.5	12.12	0.06	6.63			
7	2.26	213	7.5	17.22	0.04	7.34			
8	1.84	459	7.5	26.53	0.04	7.62			
9	2.54	224	7.5	25.15	0.04	6.77			
10	2.26	195	7.5	22.53	0.04	7.12			
11	2.11	265	7.5	26.61	0.03	7.46			
12	2.61	247	7.5	24.11	0.03	5.88			
13	2.30	189	15.0	24.40	0.06	6.19			
14	2.45	237	7.5	23.37	0.16	6.97			
15	2.02	347	7.5	15.43	0.08	7.00			
16	2.20	497	7.5	21.16	0.04	7.43		205290	COD、氨 氮进水、 出水浓度 为企业自 测数据。
17	2.25	270	7.5	14.42	0.05	6.91			
18	2.34	226	7.5	13.67	0.05	6.89			
19	2.37	406	7.5	16.42	0.05	7.55			
20	2.40	201	7.5	20.26	0.05	6.62			
21	2.31	195	7.5	20.57	0.14	7.84			
22	2.04	875	7.5	19.79	0.07	15.06			
23	2.23	113	35.0	20.04	0.06	14.09			
24	2.19	139	27.0	25.78	0.06	15.88			
25	2.03	110	7.5	16.80	0.03	15.47			
26	2.02	103	24.0	21.65	0.03	13.20			
27	2.18	122	7.5	21.38	0.06	15.23			
28	2.13	140	7.5	24.67	0.07	14.77			
29	2.43	405	7.5	25.04	0.03	14.50			
30	2.39	157	7.5	24.19	0.14	14.33			
31									
合计 (或加 权平 均)	66.47	281	9.9	20.96	0.09	258.44	0.00		

# 大涌镇污水处理厂每月运行情况记录表

企业单位名称(盖章): 大涌镇污水处理有限公司 填报日期: 2021年10月

日期	处理水量 (万吨)	COD(毫克/升)		氨氮(毫克/升)		污泥产生量 (含水率 80%) (千 克)	回用水量 (万吨)	用电量 (千瓦 时)	备注
		进水	出水	进水	出水				
1	2.22	165	7.5	23.95	0.06	16.36			
2	2.04	255	7.5	26.04	0.06	17.02			
3	1.62	147	7.5	32.01	0.05	15.27			
4	2.05	161	7.5	27.55	0.02	15.66			
5	2.28	345	7.5	25.60	0.03	15.42			
6	2.20	152	7.5	23.17	0.10				
7	2.19	137	7.5	22.43	0.03	15.42			
8	2.21	154	7.5	22.67	0.03	13.55			
9	2.27	63	7.5	18.16	0.02	15.65			
10	2.37	224	7.5	3.71	0.02	13.30			
11	2.20	42	7.5	3.60	0.08	13.71			
12	2.00	166	7.5	8.47	0.02	15.18			
13	2.40	263	7.5	8.59	0.02	14.42			
14	2.43	52	7.5	7.24	0.01	7.22			
15	2.29	103	7.5	13.54	0.02	15.90			
16	2.35	97	7.5	11.82	0.03	16.01		207495	
17	2.32	115	7.5	18.75	0.03	8.55			
18	2.52	91	7.5	17.94	0.08	8.32			
19	2.34	210	7.5	18.74	0.49	12.38			
20	2.29	367	7.5	20.28	0.25	4.32			
21	2.28	165	7.5	20.30	0.05	13.41			
22	2.23	119	7.5	21.44	0.03	13.11			
23	2.30	107	7.5	21.58	0.02	4.51			
24	2.33	127	7.5	22.45	0.04	6.23			
25	2.27	125	7.5	21.57	0.47	12.42			
26	2.29	192	7.5	23.12	0.03	10.30			
27	2.11	129	7.5	22.82	1.84	11.34			
28	2.26	411	7.5	25.52	4.06				
29	2.06	157	7.5	27.26	0.02	6.47			
30	2.23	169	7.5	25.38	0.06	7.07			
31	2.25	152	7.5	29.02	0.04	7.47			
合计 (或加 权平 均)	69.21	167	7.5	19.83	0.26	345.99	0.00		COD、氨 氮进水、 出水浓度 为企业自 测数据。

# 大涌镇污水处理厂每月运行情况记录表

企业单位名称(盖章): 大涌镇污水处理有限公司

填报日期: 2021年11月

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率 80%) (千 克)	回用水量 (万吨)	用电量 (千瓦 时)	备注
		进水	出水	进水	出水				
1	2.27	137	7.5	31.45	0.05	7.15			
2	2.32	181	7.5	25.03	1.35	13.08			
3	2.41	149	7.5	31.53	0.08	5.60			
4	2.28	161	7.5	19.64	0.60	6.53			
5	2.28	105	7.5	28.06	0.04	5.78			
6	2.31	112	7.5	25.59	0.28	7.24			
7	1.98	143	7.5	28.53	0.50	7.24			
8	2.21	120	7.5	28.57	0.09	7.62			
9	2.27	108	7.5	25.44	0.01	6.57			
10	2.30	154	7.5	26.29	0.10	12.36			
11	1.97	118	7.5	27.57	0.04	10.55			
12	2.30	148	22.0	27.78	0.22	14.10			
13	2.22	173	7.5	24.33	0.01	7.13			
14	2.23	110	7.5	27.09	0.04	6.47			
15	2.10	162	7.5	28.29	0.31	15.21			
16	2.04	119	7.5	27.72	0.06	3.91		186570	COD、氨氮进水、出水浓度为企业自测数据。
17	1.66	134	7.5	30.55	0.08	6.82			
18	1.53	193	17.0	30.47	0.32	6.25			
19	1.51	263	7.5	33.22	0.02	6.59			
20	1.82	254	7.5	31.11	0.16	5.63			
21	1.71	171	7.5	30.23	0.05	4.36			
22	1.54	253	7.5	27.04	0.71	4.34			
23	2.05	278	7.5	28.67	0.10				
24	2.01	265	7.5	25.42	0.07	6.92			
25	2.03	129	7.5	27.06	0.06	7.31			
26	2.10	201	7.5	30.49	0.16	7.23			
27	2.12	178	7.5	29.20	0.02	7.56			
28	2.00	184	15.0	22.15	0.29	5.73			
29	2.06	177	7.5	27.30	0.03	7.00			
30	1.85	155	7.5	26.73	1.11	6.31			
31									
合计 (或加 权平 均)	61.50	168	8.6	27.75	0.23	218.59	0.00		

# 大涌镇污水处理厂每月运行情况记录表

企业名称名称(盖章): 大涌镇污水处理有限公司						填报日期:	2021年 12月		
日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率 80%) (千 克)	回用水量 (万吨)	用电量 (千瓦 时)	备注
		进水	出水	进水	出水				
1	1.96	174	7.5	29.95	0.36	7.04			
2	1.90	192	7.5	30.65	1.23	14.18			
3	1.95	129	7.5	21.18	0.16	5.60			
4	2.00	187	7.5	28.53	1.25	13.46			
5	2.01	220	7.5	35.48	0.90	5.08			
6	1.80	172	7.5	25.80	0.29	5.62			
7	1.54	198	7.5	26.28	0.09	15.03			
8	1.36	301	7.5	27.75	0.78	3.96			
9	1.41	298	7.5	29.08	0.27	13.80			
10	1.39	128	7.5	28.68	0.17	6.22			
11	1.30	253	7.5	14.17	0.29	8.98			
12	1.66	274	7.5	26.69	0.10	8.55			
13	1.60	202	7.5	36.81	0.17	12.77			
14	1.80	191	7.5	29.58	0.05	5.03			
15	1.69	166	7.5	33.92	0.33	11.72			
16	1.73	211	7.5	33.79	0.06	12.59			
17	1.88	190	7.5	28.64	0.20				
18	1.93	122	7.5	28.81	0.43	7.13			
19	1.89	294	7.5	32.06	0.01	14.08			
20	1.79	186	7.5	35.95	0.01	11.97			
21	1.84	154	7.5	19.04	0.03	4.78			
22	1.88	283	7.5	11.31	0.08	13.95			
23	1.86	294	7.5	19.73	0.05	5.44			
24	1.80	294	7.5	23.39	0.20	12.52			
25	1.94	194	7.5	22.35	0.02	12.46			
26	1.91	123	7.5	24.75	0.04	6.39			
27	1.93	149	7.5	22.33	0.03	14.07			
28	1.90	197	7.5	23.59	0.16	6.00			
29	1.88	166	7.5	26.87	0.02	13.27			
30	1.81	193	7.5	26.99	0.02	10.17			
31	1.98	247	7.5	26.82	0.07	7.69			
合计 (或加 权平 均)	55.35	206	7.5	26.81	0.25	289.55	0.00		

179370

COD、氨氮进水、出水浓度为  
企业自测数据。