

中山市珍家山污水处理有限公司运行情况记录表

2021年1月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	9.6052	131	15.5	22.5	1.3	57.17	/	652813	注：cod、氨氮 进出水 浓度均 为企业 自测数 据
2	9.0932	154	15	20	1.8	19.55	/		
3	8.2712	137	15	19.8	1.19	50.39	/		
4	8.3589	153	15	21	1.91	33.95	/		
5	8.0092	140	15	23	1.7	34.35	/		
6	8.6804	165	15	21.2	1.05	48.25	/		
7	8.4251	116	15	21.8	1.36	46.86	/		
8	8.2346	143	15	21.5	1.16	0	/		
9	8.3227	225	15	24.4	2.07	0	/		
10	8.8582	109	15	19.3	1.56	0	/		
11	8.0129	123	15	21.3	0.87	0	/		
12	8.0452	130	15	20.3	1.06	0	/		
13	8.1961	134	15	22.6	0.89	0	/		
14	7.6181	159	15	24.3	0.58	0	/		
15	8.091	149	15	19.8	0.58	17.97	/		
16	8.6572	147	15	21.8	1.74	45.82	/		
17	8.459	146	15	13.8	0.36	43.12	/		
18	8.7858	140	15	23.8	0.79	24.18	/		
19	8.1042	143	15	23.4	0.87	63.39	/		
20	8.2243	148	15	20.9	0.36	9.29	/		
21	8.965	132	15	22.6	1.73	19.02	/		
22	7.1661	149	15	23.1	0.15	54.98	/		
23	8.0511	168	15.5	25.2	0.76	42.24	/		
24	7.9872	155	15	22.7	0.41	48.34	/		
25	8.6516	160	15	21.2	0.46	33.85	/		
26	8.6873	162	20	23	0.92	51.53	/		
27	9.0475	161	17	22	1.24	37.98	/		
28	8.5146	143	21	21.3	0.7	49.24	/		
29	8.5354	170	5	21.9	0.67	46.8	/		
30	8.5314	176	15	18.2	0.18	21.18	/		
31	8.8736	180	15	19.9	1.98	33.76	/		
合计 (或加权 平均)	261.0633	150	15.1	21.5	1.06	933.21	/	652813	

中山市珍家山污水处理有限公司运行情况记录表

2021年2月

企业单位名称 (盖章): 中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	8.3265	192	15	20.9	0.64	34.18	/	556414	注: cod、氨氮 进出水 浓度均 为企业 自测数 据
2	8.6218	160	15	16.7	0.61	29.9	/		
3	8.7855	151	15	18	0.26	44.69	/		
4	8.9415	155	15	28.2	3.36	39.92	/		
5	7.8281	162	20	23.6	1.33	36.51	/		
6	8.5118	201	14	22.4	0.34	44.68	/		
7	8.9189	148	8	21.9	0.16	39.56	/		
8	8.5335	148	6	19.8	0.22	28.07	/		
9	8.9444	141	19	18.9	0.56	40.88	/		
10	9.0883	67	13	11.1	0.17	48.3	/		
11	9.0911	139	6.5	10.7	0.09	69.21	/		
12	8.7087	124	15	15.1	0.21	37.94	/		
13	8.8633	135	3	16.9	0.19	35.38	/		
14	8.467	105	5	21.2	0.55	43.39	/		
15	7.9809	162	13	19.6	0.33	34.95	/		
16	8.3936	108	7	17.9	0.43	27.94	/		
17	8.8338	121	9	19.3	0.48	62.08	/		
18	8.8114	123	14	19.4	0.41	82.9	/		
19	9.0366	138	11	20.3	0.64	46.33	/		
20	9.1679	121	10	22.2	1.5	78.97	/		
21	7.926	117	17	24.1	2.28	149.79	/		
22	8.4719	186	3	21.8	0.4	94.06	/		
23	9.8123	215	11	21.8	1.06	85.71	/		
24	9.8407	282	13	21.3	0.3	58.46	/		
25	10.2348	218	15	20.6	0.18	53.51	/		
26	9.9365	209	5.5	21	0.11	109.37	/		
27	9.1908	137	13	16.7	0.08	103.1	/		
28	9.7987	147	17	20.1	0.19	87.2	/		
/	/	/	/	/	/	/	/		
/	/	/	/	/	/	/	/		
/	/	/	/	/	/	/	/		
合计 (或加权 平均)	249.066	155	11.7	19.7	0.598	1646.98	/	556414	

中山市珍家山污水处理有限公司运行情况记录表

2021年3月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	9.9989	129	12	13.3	0.67	97.18	/		
2	10.3894	226	16.5	18	1.08	88.68	/		
3	10.5044	126	3	12.6	0.31	96.36	/		
4	10.3332	114	13.5	18.2	0.44	70.64	/		
5	10.3979	100	10.5	20.4	0.96	58.41	/		
6	10.3534	141	18	17.8	0.43	80.02	/		
7	9.8654	71	3	12.2	0.11	102.62	/		
8	10.3851	111	9	14.1	0.03	65.13	/		
9	10.7062	226	7	17.3	0.35	98.03	/		
10	10.1902	151	8	16.8	1.25	70.16	/		
11	10.5308	115	4	13.8	0.36	98.36	/		
12	10.6239	108	4	19.5	0.56	96.5	/		
13	10.1504	103	4.5	18.2	1.1	93.9	/		
14	9.797	122	15.5	17.2	0.27	92.98	/		
15	10.1326	93	9.5	18.8	0.52	83.49	/		
16	9.3404	156	9	17.8	0.81	70.85	/	607097	注：cod
17	10.4725	147	6	23	1.16	69.97	/		、氨氮
18	10.2009	145	5	20.8	0.62	75.31	/		进出水
19	9.9935	134	7.5	24	0.51	73.29	/		浓度均
20	10.1486	141	9	24	0.42	62.13	/		为企业
21	10.0353	138	10	24.2	0.41	47.27	/		自测数
22	9.7894	165	4	23.1	0.21	56.36	/		据
23	9.6894	170	7	20.1	0.58	85.18	/		
24	10.2091	126	8	23.6	0.71	76.3	/		
25	10.0008	145	9.5	18.8	0.82	62.28	/		
26	10.7948	111	15	23.6	0.89	59.74	/		
27	10.4081	134	10	21.9	0.37	84.07	/		
28	10.0827	128	8	20.5	0.46	59.37	/		
29	10.6366	124	14.5	19.7	0.94	43.79	/		
30	10.6069	145	8	18	0.8	62.66	/		
31	10.7132	182	13	18.4	0.47	99.42	/		
合计 (或加权 平均)	317.481	136	9.1	19	0.602	2380.45	/	607097	

中山市珍家山污水处理有限公司运行情况记录表

2021年4月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	10.6804	162	7.5	17.8	0.13	81.53	/	611956	注：cod、氨氮 进出水 浓度均 为企业 自测数 据
2	10.782	101	7.5	23.5	0.2	58.32	/		
3	10.7794	124	7.5	20.3	0.58	56.13	/		
4	11.0792	100	7.5	21.7	0.24	57.42	/		
5	11.1021	137	29	19.3	0.44	59.36	/		
6	11.1355	117	7.5	19.4	0.95	68.78	/		
7	11.3376	112	7.5	20	0.9	58.49	/		
8	10.9995	154	7.5	18.8	0.9	30.19	/		
9	11.38	110	10	15.1	0.37	57.5	/		
10	11.2344	120	10	18.1	0.22	58.78	/		
11	10.9556	98	2	19.3	0.54	57.12	/		
12	11.2254	157	6	21.8	0.44	59.18	/		
13	11.2026	126	22	17.7	0.64	58.82	/		
14	11.0485	121	7.5	18.8	0.79	58.3	/		
15	11.2456	144	7.5	16.5	0.73	71.03	/		
16	11.1903	121	7.5	18.7	0.71	50.79	/		
17	10.9009	114	7.5	18.4	0.23	62.01	/		
18	11.2194	139	15.5	17.4	0.55	59.66	/		
19	11.3375	81	7.5	14.9	0.48	56.99	/		
20	10.8689	93	15	20.1	0.27	61.37	/		
21	10.7377	115	7.5	20.6	0.46	58.2	/		
22	11.1683	159	15.5	20.7	0.74	59.32	/		
23	10.9827	127	25	21.9	0.33	58.16	/		
24	10.3295	91	7.5	19.4	0.2	58.81	/		
25	10.9721	106	7.5	19.1	0.42	58.77	/		
26	10.9452	114	17	22.1	0.44	71.13	/		
27	10.5851	78	7.5	19.7	0.42	67.87	/		
28	10.9131	170	7.5	17.8	0.54	77	/		
29	11.0759	142	7.5	14.1	0.13	48.47	/		
30	10.8967	113	7.5	16.3	0.21	79.24	/		
/	/	/	/	/	/	/	/		
合计 (或加权 平均)	330.311	122	10.3	19	0.475	1818.74	/	611956	

中山市珍家山污水处理有限公司运行情况记录表

2021年5月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含 水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	10.892	120	16	19.1	0.18	46.86	/		
2	10.9416	129	7.5	15.3	0.45	67.45	/		
3	11.0263	90	7.5	14.7	0.14	35.74	/		
4	11.0251	130	7.5	14.2	0.1	67.75	/		
5	10.1826	99	7.5	11.2	0.07	45.39	/		
6	11.0798	116	7.5	12.7	0.15	71.02	/		
7	11.1108	97	7.5	17.7	0.08	45.22	/		
8	11.0948	114	7.5	19.6	0.27	78.93	/		
9	10.8942	111	7.5	21.5	0.86	20.14	/		
10	10.7639	97	7.5	18.9	0.21	59.12	/		
11	11.1024	89	7.5	17.7	0.2	59.85	/		
12	10.5563	102	7.5	18.7	0.14	60.5	/		
13	11.1248	155	7.5	20.1	0.13	60.43	/		
14	10.9937	139	7.5	18.6	0.12	60.37	/		
15	11.1991	96	7.5	21.1	0.22	59.16	/		
16	11.0721	106	7.5	20.2	0.43	60.77	/	662772	
17	10.9487	152	7.5	22.1	0.69	60.15	/		
18	10.8151	78	7.5	24.5	0.56	59.56	/		
19	10.8695	106	7.5	18.9	0.52	59.63	/		
20	10.5022	103	7.5	21.6	0.46	89.69	/		
21	10.8373	96	7.5	22.1	0.33	57.35	/		
22	11.035	102	23	20.6	0.28	89.66	/		
23	11.006	87	7.5	20.1	0.24	88.07	/		
24	10.8708	101	7.5	17.9	0.46	87.64	/		
25	10.7887	74	7.5	15.3	0.24	87.38	/		
26	11.1477	80	7.5	13.7	0.11	87.82	/		
27	11.4583	91	7.5	17.3	0.23	89.01	/		
28	11.2969	123	17	19.4	0.94	87.06	/		
29	11.2935	97	7.5	20.4	0.6	58.19	/		
30	10.9439	102	7.5	20.3	0.82	87.56	/		
31	10.9977	175	7.5	21	0.5	61.19	/		
合计 (或加权 平均)	339.8708	108	8.59	18.6	0.347	2048.66	/	662772	

注：cod、氨氮进出水浓度均为企业自测数据

中山市珍家山污水处理有限公司运行情况记录表

2021年6月

企业单位名称(盖章): 中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含 水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	10.9538	72	7.5	11.8	0.27	90.65	/	613382	注: cod 、氨氮 进出水 浓度均 为企业 自测数 据
2	10.5365	55	7.5	7.62	0.08	93.33	/		
3	10.7891	147	16	12.5	0.09	60.63	/		
4	11.5158	86	23	7.84	0.21	61.72	/		
5	11.6295	164	7.5	14.7	0.08	60.25	/		
6	11.4924	126	7.5	15.1	0.55	61.97	/		
7	11.2584	108	21.8	14.8	0.09	0	/		
8	11.7454	92.41	7.5	14.8	0.37	0	/		
9	11.5047	98	7.5	15.5	0.23	61.47	/		
10	11.553	114	16	16.1	0.35	78.43	/		
11	11.034	130	7.5	17.4	0.36	42.56	/		
12	12.1869	110	7.5	12.7	0.44	39.32	/		
13	11.4584	75.32	7.5	6.08	0.05	75.14	/		
14	11.1508	68	7.5	6.82	0.08	42.22	/		
15	11.9052	64	7.5	11.1	0.11	66.18	/		
16	11.2196	84	7.5	13.6	0.06	51.48	/		
17	11.0474	105	7.5	15.9	0.97	67.77	/		
18	10.8575	113.07	7.5	16.5	1.2	20.05	/		
19	10.5867	133	7.5	21.1	1.57	59.28	/		
20	10.498	126	7.5	19.6	0.11	41.17	/		
21	10.6201	110	7.5	17.2	0.05	50.88	/		
22	11.2488	79	7.5	7	0.07	27.06	/		
23	10.7127	/	7.5	5.63	0.04	46.38	/		
24	10.7246	/	7.5	5.33	0.04	43.85	/		
25	10.7769	58.49	7.5	8.82	0.02	52.81	/		
26	10.9658	93.05	18	10.8	0.11	35.57	/		
27	10.1584	101.8	7.5	13.5	0.25	54.71	/		
28	11.8511	95.12	7.5	13.7	0.24	58.32	/		
29	11.0794	97	7.5	15.8	0.32	32.24	/		
30	10.9253	106	7.5	17.9	0.77	50.82	/		
/	/	0	/	/	/	/	/		
合计 (或加权 平均)	333.9862	100	9.43	12.9	0.305	1526.26	/	613382	

中山市珍家山污水处理有限公司运行情况记录表

2021年7月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	10.9652	154	19	17.4	0.3	13.76	/	660007	注：cod、氨氮进出水浓度均为企业自测数据，2021年7月19日因厂外管道检修，10:00至16:00停产
2	11.1499	111	18.5	19.4	0.31	48.9	/		
3	11.0762	110	7.5	18.4	0.12	62	/		
4	10.8783	123	7.5	17.9	0.05	38.41	/		
5	10.9626	122	7.5	18.6	0.06	46.53	/		
6	11.5451	109	27	18	0.02	43.5	/		
7	10.7058	111	7.5	17.5	0.03	44.45	/		
8	12.2691	105	7.5	12.8	0.08	51.39	/		
9	11.4295	83	16	12.8	0.04	67.29	/		
10	11.464	114	7.5	18	0.04	46.23	/		
11	11.0696	94	7.5	16.8	0.04	31.36	/		
12	11.6511	122	7.5	13.5	0.05	42.74	/		
13	11.7777	97	18	16.1	0.06	41.73	/		
14	11.838	94	7.5	14.8	0.08	38.13	/		
15	12.2494	125	17	15.2	0.07	53.87	/		
16	11.8819	157	7.5	13.7	0.02	47.74	/		
17	11.7948	124	7.5	12.3	0.07	56.85	/		
18	11.5104	90	7.5	12.8	0.06	88.35	/		
19	8.5253	134	7.5	12.1	0.05	74.74	/		
20	11.674	118	7.5	5.72	0.07	45.55	/		
21	12.0332	69	7.5	3.45	0.04	32.21	/		
22	11.7106	39	7.5	5.34	0.06	63.48	/		
23	11.6493	48	7.5	8.82	0.06	22.59	/		
24	11.5115	96	7.5	11.4	0.07	0	/		
25	11.2838	102	7.5	12.6	0.07	25.36	/		
26	11.8847	92	7.5	12.5	0.07	59.27	/		
27	12.2321	88	7.5	11.9	0.05	88.18	/		
28	12.125	80	7.5	14	0.07	74.84	/		
29	12.3313	122	7.5	17.9	0.18	70.25	/		
30	12.0386	161	7.5	15.8	0.11	43.41	/		
31	11.6218	99	7.5	17	0.29	54.74	/		
合计 (或加权平均)	356.84	106	9.77	14	0.087	1517.85	/	660007	

中山市珍家山污水处理有限公司运行情况记录表

2021年8月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	11.4694	138	7.5	15.6	0.08	32.08	/	651944	注：cod、氨氮进出水浓度均为企业自测数据
2	12.3529	114	7.5	15.2	0.07	25.98	/		
3	12.7422	154	7.5	12.2	0.09	28.29	/		
4	12.5345	111	7.5	9.87	0.06	27.33	/		
5	13.2523	94	7.5	9.53	0.06	15.24	/		
6	12.7458	71	7.5	13.4	0.13	17.07	/		
7	11.4748	81	15	10.7	0.06	17	/		
8	11.043	77	17	12.2	0.07	0	/		
9	11.2243	89	16	10.9	0.09	29.76	/		
10	11.9974	50	7.5	4.35	0.09	32.69	/		
11	12.1539	77	7.5	6.47	0.15	44.36	/		
12	11.9605	52	7.5	5.74	0.04	0	/		
13	11.3716	41	7.5	7.11	0.09	28.93	/		
14	11.4959	54	7.5	8.31	0.07	30	/		
15	11.7003	119	7.5	10.1	0.04	16.97	/		
16	11.2478	64	7.5	13.7	0.43	23.05	/		
17	11.1699	78	7.5	12.9	0.13	16.05	/		
18	11.4892	76	7.5	12.4	0.11	0	/		
19	11.4962	89	7.5	15.4	0.11	45.35	/		
20	11.5294	69	7.5	13	0.11	45.22	/		
21	12.2195	71	7.5	12.8	0.08	30.52	/		
22	11.6415	75	7.5	13.8	0.13	29.01	/		
23	12.3387	114	16	13.6	0.5	27.68	/		
24	11.669	89	16	13.4	0.34	36.99	/		
25	12.2084	44	15	10	0.14	36.41	/		
26	11.906	71	7.5	10.5	0.19	30.27	/		
27	12.3333	87	7.5	13.4	0.21	68.11	/		
28	11.7004	62	7.5	12.6	0.29	77.61	/		
29	11.8851	72	16	15.2	0.05	67.59	/		
30	12.037	109	7.5	16	0.15	99.11	/		
31	11.6703	119	7.5	16.8	0.2	48.81	/		
合计 (或加权平均)	368.061	84.5	9.36	11.8	0.14	1027.48	/	651944	

中山市珍家山污水处理有限公司运行情况记录表

2021年9月

企业单位名称(盖章): 中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	11.4697	97	7.5	17.4	0.15	44.26	/	638934	注: cod、氨氮 进出水 浓度均 为企业 自测数 据
2	11.3837	114	7.5	14.8	0.09	54.81	/		
3	11.4215	87	7.5	17.5	1.75	50.44	/		
4	11.3896	73	7.5	18.2	0.12	42.04	/		
5	11.5448	86	16	15.5	0.04	29.36	/		
6	11.8058	71	25	17	0.07	38.9	/		
7	11.5405	79	7.5	15.8	0.07	35.44	/		
8	11.7814	105	7.5	17.1	0.04	59.91	/		
9	12.0983	96	20.5	16.2	0.04	41.97	/		
10	12.3616	112	7.5	13.9	0.01	81.6	/		
11	12.0066	80	20	15.7	0.04	36.26	/		
12	11.9914	94	7.5	14.6	0.07	22.51	/		
13	11.6775	122	7.5	16.2	0.06	44.62	/		
14	12.0016	83	7.5	15.4	0.05	50.76	/		
15	11.4203	106	7.5	16.6	0.04	41.9	/		
16	11.3449	82	7.5	11.2	0.05	33	/		
17	11.5781	60	7.5	7.13	0.02	40.38	/		
18	11.7475	78	7.5	9.18	0.05	36.23	/		
19	11.8825	77	7.5	12.6	0.05	25.1	/		
20	12.6219	149	7.5	14.5	0.06	40.46	/		
21	12.4712	77	7.5	13.7	0.16	41.67	/		
22	12.5423	88	7.5	13.9	0.08	65.24	/		
23	12.5779	102	7.5	12.5	0.29	14.35	/		
24	12.6198	104	7.5	9.09	0.03	31.87	/		
25	12.5119	72	7.5	12.5	0.03	48.61	/		
26	12.5412	94	7.5	14.7	0.06	50.11	/		
27	12.5364	98	7.5	14.4	0.05	36.57	/		
28	11.9557	69	7.5	14.8	0.03	47.97	/		
29	12.1525	93	7.5	17	0.05	91.34	/		
30	12.2186	121	7.5	17.2	0.69	69.81	/		
/	/	/	/	/	/	/	/		
合计 (或加权 平均)	359.197	92.5	9.2	14.5	0.143	1347.49	/	638934	

中山市珍家山污水处理有限公司运行情况记录表

2021年10月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	12.7005	115	7.5	16	0.27	77.25	/		
2	12.852	111	7.5	17.9	0.43	91.83	/		
3	12.5443	74	7.5	12.6	0.11	64.35	/		
4	12.099	81	7.5	12.7	0.03	72.59	/		
5	12.4488	80	7.5	17.03	0.41	74.75	/		
6	12.6107	88	7.5	16	0.16	63.36	/		
7	12.9055	104	7.5	17.7	0.29	47.76	/		
8	13.2918	64	7.5	4.55	0.41	63.28	/		
9	13.6675	31	7.5	2.38	0.03	60.64	/		
10	12.9415	58	7.5	1.78	0.1	27.55	/		
11	12.0967	60	7.5	6.15	0.01	25.49	/		
12	12.1794	78	7.5	8.76	0.02	42.67	/		
13	12.8352	83	7.5	7.02	0.01	36.49	/		
14	12.4579	48	7.5	5.39	0.01	8.98	/		
15	12.4566	51	7.5	6.24	0.02	30.94	/		
16	12.413	31	7.5	8.43	0.04	26.36	/	626372	
17	11.8108	42	7.5	9.97	0.04	35.5	/		
18	12.6004	35	7.5	10.5	0.09	50.48	/		
19	13.1824	57	7.5	13.6	0.29	48.81	/		
20	12.668	47	7.5	15	0.6	33.45	/		
21	13.2488	66	7.5	16	0.23	45.12	/		
22	12.61	74	7.5	15.4	0.24	23.66	/		
23	12.7716	38	7.5	16.9	0.02	24.85	/		
24	12.3883	124	7.5	17	0.07	38.23	/		
25	9.9815	90	7.5	17.3	0.02	23.33	/		
26	8.8078	59	7.5	14.5	0.03	27.17	/		
27	10.3191	252	7.5	18.7	0.09	41.51	/		
28	13.2245	151	7.5	19.7	0.03	26.61	/		
29	10.5999	95	7.5	15.6	0.01	12.34	/		
30	13.3641	55	7.5	15.7	0.04	38.56	/		
31	10.7148	53	7.5	15.7	0.02	39.24	/		
合计 (或加权平均)	380.792	76.3	7.5	12.5	0.139	1323.15	/	626372	

注：cod、氨氮进出水浓度均为企业自测数据；因火炬区污水泵站电缆接驳2021年10月26日11:00-16:00配电房低压室停电，停产。

中山市珍家山污水处理有限公司运行情况记录表

2021年11月

企业单位名称（盖章）：中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	11.0807	73	7.5	13.8	0.07	31.52	/	642011	注：cod、氨氮 进出水 浓度均 为企业 自测数 据
2	11.437	48	7.5	13.7	0.06	51.17	/		
3	13.64	55	7.5	11.7	0.06	43.01	/		
4	13.5127	108	7.5	15.9	0.05	39.64	/		
5	13.6889	117	7.5	14	0.06	25.26	/		
6	13.6087	43	7.5	16.1	0.02	46.62	/		
7	14.0005	80	7.5	17.7	0.02	30.04	/		
8	13.5628	64	7.5	18	0.07	28.33	/		
9	12.895	58	7.5	20.1	0.06	39.49	/		
10	12.616	64	7.5	18.7	0.05	54.4	/		
11	12.4483	87	7.5	18.4	0.11	49.79	/		
12	12.7597	113	7.5	16.4	0.05	21.91	/		
13	12.1894	69	7.5	17	0.03	72.59	/		
14	12.9662	86	7.5	18.7	0.02	50.57	/		
15	13.7591	64	7.5	18.4	0.45	46.24	/		
16	14.7902	77	7.5	20.2	0.64	32.66	/		
17	14.3245	67	7.5	18.2	0.07	47.56	/		
18	14.0535	99	7.5	19.9	0.73	48.16	/		
19	9.1721	83	7.5	19.1	0.03	28.46	/		
20	12.6488	68	7.5	16.4	0.04	38.67	/		
21	13.1531	97	7.5	15.6	0.08	60.69	/		
22	13.151	83	7.5	19	0.23	25.16	/		
23	13.0807	90	7.5	17.9	0.07	50.35	/		
24	13.4523	73	7.5	17.4	0.13	34.67	/		
25	14.3388	101	7.5	18	0.1	33.76	/		
26	14.1167	85	7.5	17.5	0.03	43.72	/		
27	13.8731	69	7.5	15	0.19	71.48	/		
28	13.7974	69	7.5	17.8	0.07	49.91	/		
29	13.7563	77	7.5	16.6	0.16	36.7	/		
30	14.4809	89	7.5	20	0.95	59.54	/		
/	/	/	/	/	/	/	/		
合计 (或加权 平均)	396.3544	78.7	7.5	17.3	0.164	1292.07	/	642011	

中山市珍家山污水处理有限公司运行情况记录表

2021年12月

企业单位名称 (盖章) 中山市珍家山污水处理有限公司

日期	处理水量 (万吨)	COD (毫克/升)		氨氮 (毫克/升)		污泥产生量 (含水率80%) (吨)	回用水量 (万吨)	用电量 (千瓦时)	备注
		进水	出水	进水	出水				
1	14.7417	150	7.5	19.2	0.95	35.98	/	692485	注: cod、氨氮 进出水 浓度均 为企业 自测数 据
2	14.7621	142	7.5	13.9	0.53	55.07	/		
3	14.8294	135	7.5	18.3	0.49	49.47	/		
4	14.9971	134	7.5	22.4	1.26	36.17	/		
5	15.0216	153	7.5	18.8	0.59	67.61	/		
6	14.7209	126	7.5	20	0.23	31.98	/		
7	14.6395	132	7.5	17.4	0.05	25.5	/		
8	14.729	106	7.5	15.8	0.58	32.69	/		
9	14.8658	116	7.5	17.2	0.66	24.08	/		
10	14.2266	107	7.5	16.6	0.3	40.19	/		
11	14.942	104	7.5	16	0.43	40.68	/		
12	14.6995	103	7.5	21.6	0.4	40.42	/		
13	13.4765	119	7.5	19.1	0.23	65.39	/		
14	13.8512	106	7.5	20.3	0.4	24.35	/		
15	13.5519	112	7.5	22.6	0.66	50.38	/		
16	13.2663	118	7.5	22.1	0.07	39.98	/		
17	12.0481	117	7.5	17.3	0.03	24.55	/		
18	12.2008	103	7.5	17.8	0.01	24.07	/		
19	12.2028	112	7.5	20.7	0.13	29.47	/		
20	11.7125	117	7.5	17.9	0.02	26.54	/		
21	12.2952	117	7.5	8.2	0.07	32.55	/		
22	12.7022	80	7.5	12.4	0.05	44	/		
23	12.4277	85	7.5	12.9	0.26	78.67	/		
24	12.4915	100	7.5	13.3	0.02	85.23	/		
25	12.3988	110	7.5	16.2	0.04	59.11	/		
26	12.2646	108	7.5	14.8	0.16	27.24	/		
27	12.3269	103	7.5	17.4	0.01	42.18	/		
28	12.2756	99	7.5	18	0.01	26.34	/		
29	12.5048	103	7.5	19.8	0.01	23.07	/		
30	12.38	114	7.5	20	0.07	57.91	/		
31	12.121	145	7.5	17.4	0.07	59.26	/		
合计 (或加权 平均)	415.674	116	7.5	17.7	0.304	1300.13	/	692485	